

Policy: #3350 – Electrical Wiring Inspection

SCOPE OF POLICY: Customers

RESPONSIBILITY: Management. Employees

---

---

**I. Policy**

Elkhorn Rural Public Power District (ERPPD) shall have the following electrical wiring inspection standards for services:

**II. Procedure**

- A. It shall be ERPPDs objective to promote the safety and protection of employees, consumers, and the general public; as well as the conservation of property belonging to ERPPD and others from accidental damage or destruction.
- B. Therefore, ERPPD shall comply with the State Electrical Act, and, to the extent practical, city or county authorities authorized to inspect Customer wiring. encourage inspections, and in certain installations as listed in Item D below, shall require an inspection of the electrical wiring where not already covered by the State Electrical Act, NEB. REV. STAT., § 81-2124.
- C. In instances where the State Electrical Act or city or county regulation requires an inspection, the inspection should be performed by an Inspector, certified by the State of Nebraska, State Electrical Division or the appropriate licensing entity.
- D. Regardless of applicability of the State Electrical Act, city, or county regulation, ERPPD shall require inspection on the following services and the owner shall submit an application for inspection:
  1. All new irrigation services (electric irrigation pumps, pivot drives, lift pumps, etc.)
  2. New services and customer services, uprates, altered or improved service installations of 300 volts or higher, phase to phase.
  3. Existing services seeking reconnection that have been previously disconnected due to unsafe wiring practices.

To the extent an above service is not covered by the State Electrical Act or a city or county regulation, the inspection shall be conducted by a licensed electrician certifying the work completed meets all NESC regulations.

- E. ERPPD reserves the right to terminate the service until the customer has requested an electrical inspection by the State Electrical Inspector, corrected the violation or hazards, and has received verification of corrections.