

ELKHORN RURAL PUBLIC POWER DISTRICT

POLICY #3350

ELECTRICAL WIRING INSPECTION POLICY

SUBJECT: Electrical Wiring Inspection Policy for All Irrigation Services and Installations of 300 Volts and Above.

1. It shall be the District's objective to promote the safety and protection of employees, consumers, and the general public; as well as the conservation of property belonging to the District and others from accidental damage or destruction.
2. Therefore, the District shall encourage inspections, and in certain installations as listed in Item 4 below, shall require an inspection of the electrical wiring where not already covered by the State Electrical Act, Nebraska Revised Statute, § 81-2124.
3. The inspection should be performed by an Inspector, certified by the State of Nebraska, State Electrical Division.
4. The owner shall submit an application for inspection upon making a request for a new electrical service or an electrical service uprate or improvement for the following electrical services:
 - A. All new irrigation services (electric irrigation pumps, pivot drives, lift pumps, etc.)
 - B. New services and customer services, uprates, altered or improved service installations of 300 volts or higher, phase to phase.
 - C. Existing services that have been disconnected due to unsafe wiring practices.
5. Elkhorn Rural Public Power District reserves the right to terminate the service until the consumer has requested an electrical inspection by the State Electrical Inspector, corrected the violation or hazards, and has received verification of corrections.

Adopted: August 14, 1990
Revised: May 9, 2000
Reviewed: September 11, 2000
Reviewed: October 12, 2010